


(4) 1/2"-13 HEX HD SS
CAP SCREWS W./FLAT
RUBBER AND STEEL
WASHERS.



1 1/2" RAISED LETTERS
(RECESSED FLUSH)


(2) CLOSED PICKHOLES

(4) 7/8" DIAMETER HOLES
ON 33 3/4" BOLT CIRCLE

PATTERN REFERENCE

PLAN

1/4" DIA. NEOPRENE
GASKET



SECTION

NOTES

1. FOR USE IN UNPAVED EASEMENT AREAS WHICH REQUIRE WATER TIGHT FRAME AND COVERS.
2. USE NEVER-SEIZE LUBE ON SCREWS AND BOLTS.
3. MANUFACTURER'S NAME MUST APPEAR ON FRAME AND COVER.
4. MACHINE SURFACE.
5. COVER SHOULD READ "CHARLES COUNTY WATER" FOR WATER USE.

HEAVY DUTY
MATERIAL ASTM A48 CL30
UNIT WEIGHT: 360 LBS

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 6/29/95
DIRECTOR OF DEVELOPMENT SERVICES DATE

[Signature] 6/29/95
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

WATER TIGHT EASEMENT
FRAME & COVER
(BOLT DOWN)

REVISIONS:

S
3.02